



VOC Content Test Certificate

Wednesday April 20th, 2011

Supplier: Sika Australia Pty Ltd (55 Elizabeth Street, Wetherill Park NSW 2164)

Sample Description: Sikalastic® 560 one-component, elastic, moisture curing polyurethane waterproof membrane

Date Tested: September 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	Sikalastic® 560
Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	
Architectural sealant 250 grams per Litre as VOC content material	40 grams per Litre as VOC content material
Specification	Sikalastic® 560
Green Building Council of Australia Green Star Office Design V3 IEQ-13	
Architectural sealant 250 grams per Litre as VOC content material	40 grams per Litre as VOC content material

Dr. Vyt Gamys
 PhD, BSc(Hons) AImm, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0909-12a